




Plan View

Project: Brown Jug Liquors

35°F Cooler,
40'-4" W x 42' D x 8'-4" H
WITH FLOOR,
208-230V/3ph/60hz



Project Name:
Brown Jug Liquors


Project Address:
6205 Carr Street
Arvada, CO 80004

Date:
07/12/2022

ANY QUESTIONS?
Call or Email:
Mark Bennett
Project Manager
(303)437-2976


markb@
industrialrefrigerationco.com

REVISION E



Condensing Unit Location
TBD Outside on Roof

Drain Location
TBD (Within 20'
of drain)



* Capacities shown are Application Capacities reflecting nominal operation at 37°F Fd. For models within the scope of the DOE AISEF (Annual Walk-In Energy Factor) standard, the Net Capacity is determined by the AISEF 1250 test method. DOE will publish this compliance date at www.regulations.gov.



**INDUSTRIAL REFRIGERATION
AND DESIGN, INC.**
10750 Irma Drive, Unit #12
Northglenn, CO 80233

This Drawing set is intended Solely for conducting business between the named Client and Industrial Refrigeration and Design, Inc. If you are not the intended recipient, you are hereby notified that any review, dissemination, distribution, or duplication of these drawings are strictly prohibited.